

Stage 2 Disinfection Byproducts Rule Compliance Monitoring Plan

Ground water system 500 - 9,999 population

Water system name: _____ PWS# 41 _____

Monitoring locations:

We will be taking a dual sample set (i.e. a set of two samples collected at the same time and same location, with one sample analyzed for TTHM and the other sample analyzed for HAA5) at **two locations**. A dual sample set will be collected at the highest TTHM location and the highest HAA5 location in the system.

Highest TTHM monitoring location: _____
Sample Site ID/Address/Location

Highest HAA5 monitoring location: _____
Sample Site ID/Address/Location

Monitoring dates:

Monitoring must occur during the month of highest TTHM & HAA5 concentrations or warmest water temperature. Based on this requirement, compliance monitoring will begin **June / July / August/ September 2014** and continue **annually** thereafter.

Circle Month

Note: monitoring may be reduced or increased based on routine monitoring results.

Compliance Calculations:

Compliance is based on annual monitoring results. Compliance is achieved if TTHMs are ≤ 0.080 mg/L and HAA5s ≤ 0.060 mg/L.