

# Stage 2 Disinfection Byproducts Rule Compliance Monitoring Plan

*Ground water system <500 population beginning on a reduced (every 3 years) schedule*

Water system name: \_\_\_\_\_ PWS# 41 \_\_\_\_\_

## **Monitoring locations:**

We will be taking a dual sample set (i.e. a set of two samples collected at the same time and same location, with one sample analyzed for TTHM and the other sample analyzed for HAA5) at **one location** (instead of individual TTHM and HAA5 samples at different locations) since the highest TTHM and HAA5 concentrations occur at the same location.

A dual sample set will be collected from \_\_\_\_\_.  
Sample Site ID/Address/Location

## **Monitoring dates:**

Monitoring must occur during the month of highest TTHM & HAA5 concentrations or warmest water temperature. Based on this requirement, compliance monitoring will begin **June / July / August/ September 2014** and continue **every 3 years** thereafter.  
Circle Month

*Note: First test must be done within 12 months of 10/1/13. Monitoring may be increased based on monitoring results.*

## **Compliance Calculations:**

Compliance is based on every-3-year monitoring results. Compliance is achieved if TTHMs are  $\leq 0.080$  mg/L and HAA5s  $\leq 0.060$  mg/L.