

Stage 2 Disinfection Byproducts Rule Compliance Monitoring Plan

Surface water system 500 – 3,300 population

Water system name: _____ PWS# 41 _____

Monitoring locations:

We will be taking a dual sample set (i.e. a set of two samples collected at the same time and same location, with one sample analyzed for TTHM and the other sample analyzed for HAA5) at **one location** (instead of individual TTHM and HAA5 samples at different locations) since the highest TTHM and HAA5 concentrations occur at the same location.

A dual sample set will be collected from _____.
Sample Site ID/Address/Location

Monitoring dates:

Monitoring must occur during the month of highest TTHM & HAA5 concentrations or warmest water temperature. Based on this requirement, compliance monitoring will begin **October / November / December 2013** and continue **quarterly** thereafter.
Circle Month

Note: monitoring may be reduced based on routine monitoring results.

Compliance Calculations:

Compliance is calculated after 4 consecutive quarters of monitoring is complete and is based on the locational running annual average (LRAA) at each monitoring location. Compliance is achieved if TTHMs are ≤ 0.080 mg/L and HAA5s ≤ 0.060 mg/L.