



800 NE Oregon Street, Suite 465, Portland OR 97232

Voice: (971) 673-0540

Fax: (971) 673-0556

TTY: (971) 673-0372

<http://www.healthoregon.org/fps>

mailbox.fps@state.or.us

Facilities Planning & Safety Unit

Site Inspection Check List for:

Pediatric Patient Care Unit - OAR 333-535-0050

PR# _____ Date: _____ Inspector: _____

Provider: _____

Project: _____

Address: _____

Present at Site Inspection:

Intended Occupancy Date: _____

Required **PRIOR** to Approved Inspection:

RECEIVED?

YES NO NA

Certificate of Occupancy (CO) from governing jurisdiction

MEP Close-Out verification (if required)

SITE INSPECTION:

PATIENT ROOMS:

YES NO NA

Young children and adolescents shall be housed in a patient care unit separate from adults or in a separate pediatrics room of a general nursing unit. This unit shall meet the following requirements: 333-535-0050

No more than 6 cribs in a room 333-535-0050 (1)

Patient rooms used for cribs shall contain at least 60 SF 333-535-0050 (1)

333-535-0025 PATIENT ROOMS:

YES NO NA

Except as permitted under OAR 333-535-0010 (1) or 333-535-0065, each patient care unit shall include the following:

- For new construction projects, maximum room capacity shall be two patients.
333-535-0025 (1)(a)
- For major alteration projects, the maximum room capacity shall be the present capacity or four patients, whichever is less 333-535-0025 (1)(a)
- For new construction, patient rooms shall have a minimum of 100 SF of clear floor area per bed in multiple bedrooms and 120 SF of clear floor area in single patient rooms, exclusive of toilet rooms, closets, lockers, wardrobes, alcoves, or vestibules.
333-535-0025 (1)(b)
- The dimensions and arrangements of rooms shall be such that there is a minimum clearance of 3 feet around the perimeter of the bed and any wall or any other fixed obstruction. 333-535-0025 (1)(b)
- In multiple bedrooms a clearance of 4 feet shall be available at the foot of each bed to permit the passage of equipment and beds, and 4 feet shall be provided between beds. Minor encroachments, including columns and hands-washing stations, that do not interfere with function may be ignored when calculating required space.
333-535-0025 (1)(b)
- However, if full compliance is not practical for a renovation project the Division may permit deviations from these requirements as long as patient rooms include at least 80 net SF of clear floor area per bed in a multiple bed-room and 100 net SF of clear floor area in a single patient room. 333-535-0025 (1)(b)

Windows:

- A minimum window area of 16SF shall be provided for each patient room.
333-535-0025 (1)(c)(B)
- The maximum sill height shall be 3 feet above the finished floor.
333-535-0025 (1)(c)(B)
- A minimum of 8 SF of window shall be viewable by the patient from the bed. Walls and other non-moveable items shall not block the view of the window.
333-535-0025 (1)(c)(B)
- Operable windows are not required in patient rooms. If operable windows are provided, operable sections shall be designed to inhibit possible escape or suicide attempts. 333-535-0025 (1)(c)(A)

- Windows located in outside walls shall be 20 feet or more from another building or opposite wall and 10 feet or more from the property line except when the window faces on a street or public right of way of greater than 20 feet in width.
333-535-0025 (1)(c)(C)
- For renovation projects where the exterior wall is being retained, windows shall be permitted to vary from the requirements of this subsection if approved by the Division.
333-535-0025 (1)(c)(D)
- Hand-washing stations shall be provided serving each patient room. A hand-washing station shall also be located in each patient toilet room.
333-535-0025 (1)(d)
- For new construction, the patient room hand-washing station shall also be located in each patient toilet room and shall be situation for convenient access by staff and to prevent splash on patients. 333-535-0025 (1)(d)
- For renovation projects involving single patient rooms that have private toilet room, and hand-washing station shall be located in either the toilet room or the patient room. Hand washing stations shall comply with the requirement of OAR 333-535-0260.
333-535-0025 (1)(d)
- Hand washing stations shall comply with the requirement of OAR 333-535-0260.
333-535-0025 (1)(d)
- Patient Toilet Rooms: 333-535-0025 (1)(e)
- Each patient shall have access to a toilet room without having to enter the corridor.
- One toilet room shall serve no more than four beds and no more than two patient rooms.
- The toilet room shall contain a toilet, handwashing station and bathing facilities.
- Patient toilet rooms and central bathing facilities shall comply with the requirement of OAR 333-535-0260.
- Each patient shall have a separate wardrobe, locker, or closet suitable for hanging full-length garments and for storing personal effects within the room. 333-535-0025 (1)(f)
- Visual privacy from casual observation by other patients and visitors shall be provided for each patient. The design for privacy shall not restrict patient access to the entrance, hand-washing station, toilet, or nurse call system.
333-535-0025 (1)(g)

NURSERY & WORKROOM:

YES NO NA

- Each room shall contain: 333-535-0050 (2)
- Each room serving pediatric patients shall contain no more than 8 bassinets.
- Minimum clear floor area per bassinet shall be 40 SF.
- Lavatory (equipped for hand washing)
- Nurses emergency calling system
- Glazed viewing windows for observing infants from public area and workroom

Each Nursery shall be served by a connecting workroom that shall contain:
333-535-0050 (3)

- Gowning facilities at the entrance for staff 333-535-0050 (3)(a)
- Work counter 333-535-0050 (3)(b)
- Refrigerator 333-535-0050 (3)(c)
- Storage facilities 333-535-0050 (3)(d)
- Hand Wash Station 333-535-0050 (3)(e)
- Provisions shall be made for storage of emergency carts(s) and equipment out of traffic 333-535-0050 (3)(f)
- Provisions shall be made for the sanitary storage and disposal of soiled waste 333-535-0050 (3)(i)
- Visual Control shall be provided via borrowed lights or view panels between the staff work area and each nursery. 333-535-0050 (3)(j)

EXAM ROOM:

YES NO NA

- An examination/treatment room shall be provided for pediatric and adolescent patients. 333-535-0050 (4)
- A separate area for infant examination and treatment shall be permitted within the pediatric nursery workroom. 333-535-0050 (4)
- It shall contain:
- Work Counter
- Storage Facilities
- Hand washing Station
- Examination/Treatment rooms shall have minimum floor area of 120 SF. 333-535-0050 (4)

SERVICE AREAS:

YES NO NA

The service areas in the pediatric and adolescent nursing unit shall confirm to the conditions listed in OAR 333-535-0025 and shall meet the following additional conditions: 333-535-0050 (5)

- Multipurpose or individual rooms(s) shall be provided within or adjacent to areas serving pediatric and adolescent patrons for dining, educational, and developmentally appropriate play and recreation, with access and equipment for patients with physical restrictions. 333-535-0050 (5)(a)
- Space for preparation and storage of infant formula or breast milk shall be provided in the unit or other convenient locations. 333-535-0050(5)(b)
- Patients' toilet room(s) with hand-washing stations in each room, in addition to those serving bed areas, shall be convenient to multipurpose rooms(s) and to each central bathing facility. 333-535-0050(5)(c)
- Storage closets or cabinets shall be provided for toys, and educational and recreational equipment. 333-535-0050 (d)
- Storage space shall be provided to permit exchange of cribs and adult beds. 333-535-0050 (e)
- Storage space shall be provided for equipment and supplies (including cots, recliners, extra linen, etc.) for parents who stay with the patient overnight. 333-535-0050 (f)
- Separate clean and soiled utility or holding rooms shall be provided in accordance with OAR 333-535-0260(4) and (5). 333-535-0050 (g)
- Housekeeping closet shall be provided for each nursery per OAR 333-535-0260 (8). 333-535-0050 (h)

333-535-0025 SERVICE AREAS:

YES NO NA

Provision for the services listed below shall be in or readily available to each patient care unit. The size and location of each service area will depend upon the numbers and types of beds served. Identifiable spaces are required for each of the indicated functions. Each service area may be arranged and located to serve more than one patient care unit but unless noted otherwise, at least one such service area shall be provided on each nursing floor. Where the words "room or "office" are used, a separate, enclosed space for the one named function is intended; otherwise the described area may be a specific space in another room or common area. 333-535-0025 (2)

Administrative center(s) or nurses' stations(s) shall include:
535-0025 (2)

333-

- A desk, storage and work counters
- A hand-washing station within 20 feet and not through a door, to meet infection control standards.
- May be combined with or include facilities for reception and communication systems.

- Private consultation/administrative office 333-535-0025 (2)(b)

- Charting facilities shall have sufficient surface space to provide for charting by staff and physicians to meet the functional needs of the unit.
333-535-0025 (2)(c)

- Toilet room(s) conveniently located for staff use (may be unisex)
333-535-0025 (2)(d)

- In addition to lounge facilities securable closets or cabinet compartments shall be provided for the personal articles of nursing personnel. At a minimum these shall be large enough for purses and billfolds. Coats may be stored in closets or cabinets on each floor or in a central staff locker area. 333-535-0025 (2)(e)

- Multi-purpose room(s) for staff, patients, patients' families for patient conferences, reports, education, training sessions, and consultation. These rooms shall be accessible to each patient care unit by may be located on other floors if convenient for regular use. 333-535-0025 (2)(f)

- Clean and soiled utility rooms shall be provided in accordance with OAR 333-535-0260 (5). 333-535-0025 (2)(g)

Provisions shall be made for convenient and prompt 24-hours distribution of medicine to patients. This shall be from a medicine preparation room, a self-contained medicine dispensing unit, or by another system approved by the Division. 333-535-0025 (2)(h)

- A medicine preparation room or unit shall be under the visual control of the nursing or pharmacy staff. It shall contain a work counter, hand-washing station and an electrical receptacle for a lockable refrigerator and locked storage for biologicals and drugs. Area shall have adequate lighting to easily identify drugs. 333-535-0025 (2)(h)

- A secured medicine dispensing unit may be located at the nurses' station, in the clean utility room or area, or in alcove or other space under the direct control of the nursing or pharmacy staff. Areas shall have adequate lighting to easily identify drugs. 333-535-0025 (2)(h)

- Each patient care unit shall contain a designed area for clean linen storage. This may be within the clean utility room or area, a separate closet, or a distribution system approved by the Division on each floor. If a closed cart system is used, storage may be in an alcove. 333-535-0025 (2)(i)

- There shall be a nourishment area with: 333-535-0025 (2)(j)
 - A sink
 - Work counter
 - Refrigerator
 - Storage cabinets and equipment for hot and cold nourishments between scheduled meals
 - Space for trays and dishes used for non-scheduled meal service
 - Provisions and space shall be included for separate temporary storage of unused and soiled dietary trays not picked up at mealtime.
 - A hand-washing station shall be in or immediately accessible from the nourishment area.

- Each nursing unit shall have direct access to equipment to provide ice for treatments and nourishment. Ice-making equipment may be in the clean utility room or area or at the nourishment station. Ice intended for human consumption shall be from self-dispensing icemakers. 333-535-0025 (2)(k)

- Equipment storage room(s,) or alcove(s) shall be provided for storage of equipment necessary for patient care the location of which shall not interfere with the flow of traffic. 333-535-0025 (2)(l)

- Each patient care unit shall provide sufficient storage area(s) located on the patient floor to keep the required corridor width free of all equipment and supplies, but at least 10 SF per patient bed shall be provided. 333-535-0025 (2)(l)

- If stretchers and wheelchairs are stored on the patient care unit, additional storage space shall be provided. 333-535-0025 (2)(l)

- In remodel projects that do not include bathing facilities in all existing patients rooms, common use showers and bathtubs shall be provided in accordance with OAR 333-535-0260 (6.) 333-535-0025 (2)(m)

- Space for emergency equipment such as cardio-pulmonary resuscitation (CPR) carts shall be provided. This space shall be out of traffic, under the direct control of the nursing staff and proximate to the nurses' station. 333-535-0025 (2)(n)

- One house-keeping room shall be provided for each patient care unit or nursing floor. It shall be directly accessible from the patient care unit or floor and may serve more than 1 patient care unit or a floor. 333-535-0020 (2)(o)

- At least one housekeeping room per floor shall contain a service sink or floor receptor and space for the storage of supplies and housekeeping equipment and cart. 333-535-0020 (2)(o)

- A minimum of 35 SF shall be provided for each housekeeping room. 333-535-0020 (2)(o)

- This housekeeping room shall not be used for other departments and patient care units that are specifically required by rule to have separate housekeeping rooms. 333-535-0020 (2)(o)

- Low voltage room/closet(s), electrical room/closet(s) and other technical support spaces shall be provided as required to meet the service needs of the patient care unit. 333-535-0025 (2)(p)

- Patient care units shall comply with the requirements of OAR 333-535-0260, OAR 333-535-0270, OAR 333-535-0280, OAR 333-535-0300 and OAR 333--535-0310. Additional rule requirements may apply to specialty patient care units. 333-535-0025 (3)