

**TABLE 6  
(OAR 333-535-0310)**

**RECEPTACLE REQUIREMENTS PER AREA**

(NUMBER OF DUPLEX RECEPTACLES ACCESSIBLE TO EACH BED, UNLESS OTHERWISE NOTED.)

<b>LOCATION</b>	<b>TOTAL RECEPTACLES</b>	<b>CRITICAL POWER RECEPTACLES</b>
Patient Rooms (Medical and Surgical), including holding and pre-operation	<u>4</u>	1
Treatment	<u>4</u>	2
All Critical Care, Coronary Critical Care (General)	<u>7</u>	<u>4</u>
Newborn Intensive Care	<u>7</u>	<u>4</u>
Newborn Nursery (Full Term), Special Care Nursery	2	1/2 beds
General Operating Room, Hybrid OR, Trauma Rooms used for Surgery	8	<u>6</u>
Special Procedures, including EP Lab, Cardiac Catheterization Lab	4	<u>2</u>
Surgical Cystoscopy, Endoscopy, and Bronchoscopy	4	<u>2</u>
Post-Anesthesia Care Unit	4	2
Phase 2 Recovery	2	1
Caesarean/Delivery Room	8	6
Labor/Delivery/Recovery (LDR/LDRP)	4	2
Resuscitation	7	4
Emergency Treatment	6	2
CT Scan	4	1
MRI, X-Ray, Imaging	4	1

NOTE:

- 1/ Outpatient facilities, except ambulatory surgical care facilities, are exempt from these requirements.
- 2/ If separate areas are provided for the mother and baby, provide a minimum of 1 critical power and 3 normal power receptacles for mother and a minimum of 1 critical and 1 normal receptacle for baby.
- 3/ Rooms designed for universal adaptability shall meet the highest care requirements.